

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

City of Atwater Has Levels of 1,2,3-Trichloropropane Above the Drinking Water Standard

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample results received on August 14, 2020 showed 1,2,3-trichloropropane (1,2,3-TCP) levels with a range of 0.01 ug/l to 0.097 ug/l and with an average range of 0.05 ug/l at Wells 13,14,16,17,18, and 19. This is above the standard, or maximum contaminant level (MCL), of 0.005 ug/l (0.000005 mg/l, or 5 parts per trillion).

What should I do?

- **You do not need to use an alternative water supply (e.g., bottled water).**
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing 1,2,3-TCP in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

We are working with State Water Resources Control Board-Division of Drinking Water to evaluate the water supply and researching options to correct the problem. This may include treating the water to remove 1,2,3-TCP.

We anticipate resolving the problem within 1 year.

For more information, please contact Justin Vinson at (209)357-6370 or 470 Aviator Dr, Atwater, CA 95301.

This notice is being sent to you by City of Atwater.

State Water System ID#: 2410001. Date distributed: 8/10/2020