



COMMUNITY DEVELOPMENT DEPARTMENT
750 BELLEVUE ROAD
ATWATER, CA 95301
(209) 357-6233

March 31, 2023

ADDENDUM NO. 1

PROJECT: **PALM AVENUE IMPROVEMENTS PROJECT**

BID CALL NO. 719-22; PROJECT NO 22-06

Addendum No. 1 is being issued for the Notice to Bidders, Specifications and Plans, for the **Palm Avenue Improvements Project**. Bids for this proposal are to be opened on Tuesday, April 04, 2023, at 2:00 P.M. in the City of Atwater Council Chamber, at 750 Bellevue Road, Atwater, CA 95301.

The following responses address questions identified as Bid RFI Nos. 1 through 4, from all Bid RFIs received through 3/28/2023:

1. **Bid RFI No. 1:** *Will there be a mandatory pre-bid meeting?*

Response: No.

2. **Bid RFI No. 2:** *Can a C-8 license bid for this project?*

Response: Per the specifications, contractor must have Class A license to perform the work.

3. **Bid RFI No. 3:** *On Sheet 3 Note 9 (Gas), Note 10(electrical), Note 11 (cable), and Note 12 (telephone) state "Coordinate with utility company as required". The utility companies will not respond to, nor are they authorized or able to coordinate with us. They will coordinate only with the owner. Please advise how we are to proceed and who will be responsible for the coordination with each of the four different utility companies.*

Response: The first paragraph of the Special Provision replacement of 77-1.01 GENERAL is replaced with:

"This project will include adjustments to finish grade of existing utility structure rims, frames, and covers. Existing "dry" utility structures including electrical, gas, cable television, and telephone structures will be adjusted to grade by the respective utility companies. The **City of Atwater** will prepare applications for adjustment to grade of these structures with the utility companies. Contractor is required to coordinate work as necessary to allow for the adjustment to grade upon completion of the existing sidewalk removal. The City of Atwater will pay any fees that are necessary for the adjustments to grade."

4. **Bid RFI No. 4:** *The specifications state that no work shall be performed between the hours of 7 am to 9 am and 4 pm to 6 pm. The road will need to be closed in order to perform the work. Please advise.*

Response: The 2nd paragraph of the Special Provision addition to section 12-4.01A is replaced by:

“Work on public streets is only permitted between the hours of 7 am to 7 pm, Monday through Friday. Work on Saturday and Sunday is not permitted except by special permission of the City of Atwater.”

**IF YOU SUBMIT A BID, A SIGNED COPY OF THIS
ADDENDUM No. 1 MUST BE ATTACHED THERETO.**

Sincerely,



Michael Hayes
City Engineer

Contractor _____

Signature _____

Date _____