

CA2410001 City of Atwater PFAS Raw Water and GAC Effluent PFAS Monitoring

Month, Year: May-25

Constituent	CCRD L, ng/L	NL ng/L	RL ng/L	Well 13	Well 14	Well 17	Central GAC	Well 15	GAC 15	Well 16	GAC 16	Well 18	GAC 18	Well 19	GAC 19
perfluorobutanesulfonic acid (PFBS)	3	500	5000	OFF	3.1	ND	ND	ND	ND	4.8	ND	8.2	ND	ND	ND
perfluorohexanesulfonic acid (PFHxS)	3	3	20	Line	3.1	2.2	ND	ND	ND	28	ND	52	ND	ND	ND
perfluorooctanesulfonic acid (PFOS)	4	6.5	40	OFF	ND	ND	ND	ND	ND	16	ND	42	ND	ND	ND
perfluorooctanoic acid (PFOA)	4	5.1	10	line	2.2	ND	ND	ND	ND	12	ND	29	ND	ND	ND
Sample Date				5/27/2025				5/13/2025		5/6/2025		5/8/2025		5/13/2025	