



PUBLIC WORKS DEPARTMENT
750 BELLEVUE ROAD
ATWATER, CA 95301
(209) 357-6233

August 5, 2026

ADDENDUM No. 1

PROJECT: EAST BROADWAY AVE OVERLAY

BID CALL NO. 737-26; PROJECT NO. 26-01

Addendum No. 1 is being issued to the Notice to Bidders, Specifications and Plans, for the **East Broadway Ave Overlay Project**. Bids for this proposal are to be opened on **Thursday, August 13, 2026** at 2:00 P.M. in the City of Atwater Council Chamber, at 750 Bellevue Road, Atwater, CA 95301

The following responses address questions identified as Bid RFI Nos. 1 through 4, from all Bid RFIs received through 07/16/2026:

1. **BID RFI No. 1:** *The Liquidated Damages that were referenced in "Section 8 Prosecution and Progress states that we need to Refer to Standard Specifications Section 8-1.10A Liquidated Damages. Liquidated Damages are \$4,200 per Day", however, according to that Chart and your Engineer's Estimate of \$550,000, the Liquidated Damages would be \$3,600 instead.*

Response: The liquidated damages are \$3,600 per day.

2. **BID RFI No. 2:** *Do Addendums have to be Included with the Bid?*

Response: Yes.

3. **BID RFI No. 3:** *What is the anticipated start date for this project?*

Response: September 2026.

4. **BID RFI No. 4:** *Do we need to include Equal Opportunity Certificates for our proposed subcontractors?*

Response: Yes.

5. **BID RFI No. 5:** *Does the city have any specs for the Tack Coat requirements? What is the water to tack ratio and application rate. Is the mix going to be SS-1H?*

Response: Base Binder shall be 100% PG 64-16. Edges against existing asphalt and concrete joints shall be 80% oil/ 20% water with .1 gal/sy application rate.

IF YOU SUBMIT A BID, A SIGNED COPY OF THIS ADDENDUM No. 1 MUST BE ATTACHED THERETO.

Sincerely,



Justin Vinson
Public Works Director
Public Works Department

Contractor _____

Signature _____

Date _____